



#### temperedwater.com

5330 East 25th St. Indianapolis, IN 46218 Phone (317) 261-1212 Fax (317) 261-1208




# Model 410-SC7 Thermostatic Mixing Valve Eng. No. 72146 (3/4")

#### **CAPACITIES - MODEL 410**

Pressure Drop PSI	5	10	20	30	45	60
Valve Number	Capacity					
410-GPM	5	8	12	15	20	24
410-LPM	19	30	45	56	75	91

<sup>1/4</sup> gpm when properly installed in recirculated system. The minimum flow of the Series 410 is 1 GPM.

#### FLOW CAPACITIES SINGLE STAGE - SERIES 410



The master controller shall be of the thermostatic type with liquid-filled motor. The controller shall maintain the set point temperature during periods of fluctuating inlet pressures and temperatures. Valve construction will include a lead free brass body and replaceable corrosion-resistant components. The piston and liner are stainless steel. The mixing valve shall employ an adjustable setpoint range and high temperature limit stop. Each unit will be equipped with stop and check valves for each inlet.

FINISH: Brass Rough Chrome Other				
<b>TEMP. RAN</b> 50° to 100 85° to 135 100° to 150	)°F 5°F	<b>SET POINT</b> 80°F 110°F 130°F		
Special			L	









### temperedwater.com

5330 East 25th St. Indianapolis, IN 46218 Phone (317) 261-1212 Fax (317) 261-1208





# Model 410-SC7 Eng. No. 72146 (3/4")

#### **DIMENSIONS**

Valve Number	Α	В	С	
410	9-1/2"	4-1/2"	5-1/2"	

Dimensions are for reference purposes only. For rough-in dimensions please refer to Lawler's Revit/BIM models found at temperedwater.com. Inlets & outlet are 3/4" NPT.

### **Typical Installation**

Install the mixing valve below the hot water tank or heater. If this is not possible, pipe in a heat trap as shown in Figure 1 with an approximate 2' drop.

Connect a tempered water return line as shown in Figure 1. This allows flow through both ports of the mixing valve during periods of no draw.

Install an aquastat at the tempered water return pump.

Install the water heater per manufacturer's instructions.

## Figure 1

