



Model 911®E/F ETS Emergency Tempering System for Emergency Eyewash Equipment Eng. No. 87300

The Emergency Tempering System shall consist of a water heater and 120V 20AMP heating element. The Emergency Tempering System shall incorporate an emergency mixing valve capable of controlling outlet temperature over a wide range of flows and employ a liquid-filled thermostatic motor and a stainless steel sliding piston control device. The valve shall offer positive hot water shut-off in the event of cold water supply loss and full flow cold water bypass in the event of hot water supply loss or thermostatic failure. The system shall also incorporate a device capable of flattening temperature spike through the system as well as a heat trap to prevent heat migration to the cold side of the mixing valve.

Unit supplied complete with pre-piped 40 gallon water heater, 120V 20 AMP heating element, Lawler accumulator (patent pending), 911®E/F Emergency Mixing Valve.

The hot water tank is UL listed, heating element is CSA approved and the housing has a Nema #4 rating.

For specifications on mixing valves, please refer to submittal data sheet Eng. No. 84908.

OPTIONS:

Combination Shower and Eyewash Equipment

- ☐ Stingray S 5510/5515
 - ☐ Nema 7 rated box, explosion proof
- Please call factory for pricing

Special tank or power requirements are available, please contact factory.

Model 911®E/F ETS Eng. No. 87300

DIMENSIONS

A	B
60"	27"

Dimensions are for reference purposes only. For rough-in dimensions please refer to Lawler's Revit/BIM models found at temperedwater.com.

